

Drinking Water Quality Annual Report Data 01/07/2024 to 30/06/2025

Table 9 Aesthetic (non-health related) variables															
Mid West Region	Alkalinity (as CaCO ₃)					Aluminium					Chloride				
Locality	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met
		Min	Max	Mean			Min	Max	Mean			Min	Max	Mean	
Badgingarra	6	43	89	60	(7)	2	<0.008	<0.008	<0.008	✓	6	225	240	233	✓
Bindoon /Chittering	2	91	93	92	(7)	2	<0.008	<0.008	<0.008	✓	2	170	175	173	✓
Bolgart	4	31	41	37	(7)	4	<0.008	<0.008	<0.008	✓	4	235	290	256	(8)
Calingiri	14	22	49	33	(7)	14	<0.008	0.016	<0.008	✓	14	300	475	415	(8)
Carnamah	4	7	11	9	(7)	4	<0.008	0.010	<0.008	✓	4	425	485	451	(8)
Carnarvon	2	100	110	105	(7)	2	<0.008	<0.008	<0.008	✓	2	125	150	138	✓
Cervantes	4	230	250	235	(7)	4	<0.008	<0.008	<0.008	✓	4	290	360	319	(8)
Coomberdale	5	61	71	64	(7)	5	<0.008	0.014	<0.008	✓	5	265	310	279	(8)
Coorow	5	7	18	12	(7)	5	<0.008	<0.008	<0.008	✓	5	390	480	448	(8)
Coral Bay	2	82	90	86	(7)	2	<0.008	<0.008	<0.008	✓	2	22	23	23	✓
Cue	5	37	49	40	(7)	5	<0.008	<0.008	<0.008	✓	5	110	120	115	✓
Dandaragan	5	140	210	164	(7)	5	<0.008	<0.008	<0.008	✓	5	245	265	258	(8)
Denham	2	70	72	71	(7)	2	0.010	0.014	0.012	✓	2	90	100	95	✓
Dongara/Denison	5	56	64	60	(7)	5	<0.008	<0.008	<0.008	✓	5	400	495	431	(8)
Eneabba	4	15	19	16	(7)	4	<0.008	<0.008	<0.008	✓	4	330	360	350	(8)
Exmouth	5	230	250	242	(7)	5	<0.008	<0.008	<0.008	✓	5	250	275	261	(8)
Gascoyne Junction	4	23	37	28	(7)	4	<0.008	<0.008	<0.008	✓	4	55	155	99	✓
Geraldton	7	58	66	62	(7)	7	<0.008	<0.008	<0.008	✓	7	380	415	401	(8)
Gingin	5	27	30	28	(7)	5	<0.008	<0.008	<0.008	✓	5	115	120	117	✓
Greenhead	2	17	23	20	(7)	2	<0.008	<0.008	<0.008	✓	2	290	315	303	(8)
Guilderton	4	180	200	190	(7)	4	<0.008	<0.008	<0.008	✓	4	400	445	423	(8)
Horrocks	4	110	130	118	(7)	4	<0.008	<0.008	<0.008	✓	4	590	620	606	(8)
Jurien Bay	18	170	250	213	(7)	18	<0.008	<0.008	<0.008	✓	18	210	705	361	(8)
Kalbarri	2	6	7	7	(7)	2	<0.008	<0.008	<0.008	✓	2	170	210	190	✓
Lancelin	4	200	210	203	(7)	4	<0.008	<0.008	<0.008	✓	4	245	295	270	(8)
Latham	5	33	39	37	(7)	5	<0.008	<0.008	<0.008	✓	5	310	365	347	(8)

(7) No guideline value available as per ADWG 2011.
(8) Elevated chloride is characteristic of the source supplying this locality.

Drinking Water Quality Annual Report Data 01/07/2024 to 30/06/2025

Table 9 Aesthetic (non-health related) variables															
Mid West Region	Alkalinity (as CaCO ₃)					Aluminium					Chloride				
Locality	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met
		Min	Max	Mean			Min	Max	Mean			Min	Max	Mean	
Ledge Point	4	200	220	208	(7)	4	<0.008	<0.008	<0.008	✓	4	150	155	154	✓
Leeman	2	22	22	22	(7)	2	<0.008	<0.008	<0.008	✓	7	270	315	303	(8)
Meekatharra	2	75	95	85	(7)	2	<0.008	<0.008	<0.008	✓	2	110	110	110	✓
Mingenew	4	23	29	26	(7)	4	<0.008	<0.008	<0.008	✓	4	370	415	389	(8)
Moora	2	59	63	61	(7)	2	<0.008	<0.008	<0.008	✓	2	270	280	275	(8)
Morawa	5	15	24	18	(7)	5	<0.008	<0.008	<0.008	✓	5	270	365	331	(8)
Mt Magnet	5	93	110	101	(7)	5	<0.008	<0.008	<0.008	✓	5	95	105	98	✓
Mullewa	5	69	77	73	(7)	5	<0.008	<0.008	<0.008	✓	5	400	430	414	(8)
Nabawa	5	59	63	61	(7)	5	<0.008	<0.008	<0.008	✓	5	345	430	406	(8)
New Norcia	13	36	53	44	(7)	13	<0.008	<0.008	<0.008	✓	13	360	710	492	(8)
Nilgen (Ocean Farms)	3	200	210	203	(7)	3	<0.008	<0.008	<0.008	✓	3	130	135	133	✓
Northampton	5	61	67	64	(7)	5	<0.008	<0.008	<0.008	✓	5	405	440	422	(8)
Perenjori	4	17	23	22	(7)	4	<0.008	<0.008	<0.008	✓	4	320	355	336	(8)
Piawaning	5	29	96	45	(7)	5	<0.008	<0.008	<0.008	✓	5	175	485	381	(8)
Port Kalbarri	4	99	110	102	(7)	4	<0.008	<0.008	<0.008	✓	4	320	360	343	(8)
Sandstone	5	45	60	53	(7)	5	<0.008	<0.008	<0.008	✓	5	100	160	133	✓
Seabird	2	110	110	110	(7)	2	<0.008	<0.008	<0.008	✓	2	210	220	215	✓
Seaview Park	4	160	190	168	(7)	4	<0.008	<0.008	<0.008	✓	4	80	180	108	✓
Sovereign Hills	5	210	220	212	(7)	5	<0.008	<0.008	<0.008	✓	5	195	205	200	✓
Three Springs	5	16	21	17	(7)	5	<0.008	<0.008	<0.008	✓	5	350	400	382	(8)
Watheroo	4	190	200	193	(7)	4	<0.008	<0.008	<0.008	✓	4	215	230	221	✓
Woodridge	4	47	70	56	(7)	4	0.050	0.060	0.055	✓	4	190	200	196	✓
Yalgoo	5	58	90	70	(7)	5	<0.008	<0.008	<0.008	✓	5	65	110	85	✓
Yerecoin	5	31	80	43	(7)	5	<0.008	<0.008	<0.008	✓	5	250	445	364	(8)
Yuna	5	59	65	62	(7)	5	<0.008	0.040	0.012	✓	5	405	420	413	(8)

(7) No guideline value available as per ADWG 2011.
(8) Elevated chloride is characteristic of the source supplying this locality.

Drinking Water Quality Annual Report Data 01/07/2024 to 30/06/2025

Table 10 Aesthetic (non-health related) variables															
Mid West Region	Hardness					Iron					Manganese				
Locality	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met
		Min	Max	Mean			Min	Max	Mean			Min	Max	Mean	
Badgingarra	6	41	43	42	✓	6	0.006	0.008	0.007	✓	6	<0.002	0.004	0.003	✓
Bindoon /Chittering	2	49	51	50	✓	2	0.025	0.030	0.028	✓	2	<0.002	<0.002	<0.002	✓
Bolgart	4	120	140	128	✓	4	0.020	0.030	0.023	✓	4	<0.002	<0.002	<0.002	✓
Calingiri	14	120	180	159	✓	14	0.015	0.200	0.038	✓	14	<0.002	<0.002	<0.002	✓
Carnamah	4	130	140	138	✓	4	0.015	0.360	0.110	(10)	4	<0.002	0.030	0.009	✓
Carnarvon	2	150	160	155	✓	2	<0.003	0.008	0.004	✓	2	<0.002	<0.002	<0.002	✓
Cervantes	4	320	340	328	(9)	4	<0.003	0.006	<0.003	✓	4	<0.002	<0.002	<0.002	✓
Coomberdale	5	70	98	81	✓	5	0.045	0.260	0.107	✓	5	<0.002	0.010	0.003	✓
Coorow	5	86	150	125	✓	5	0.015	0.030	0.022	✓	5	<0.002	0.004	<0.002	✓
Coral Bay	2	71	82	77	✓	2	0.010	0.035	0.023	✓	2	0.003	0.010	0.007	✓
Cue	5	36	44	39	✓	5	<0.003	0.004	<0.003	✓	5	<0.002	<0.002	<0.002	✓
Dandaragan	5	93	100	96	✓	5	0.040	0.080	0.064	✓	5	0.005	0.008	0.007	✓
Denham	2	64	64	64	✓	2	0.030	0.030	0.030	✓	2	0.005	0.006	0.006	✓
Dongara/Denison	5	120	130	122	✓	5	0.020	0.120	0.062	✓	5	<0.002	0.008	0.003	✓
Eneabba	4	99	110	102	✓	4	0.015	0.025	0.020	✓	4	<0.002	0.003	<0.002	✓
Exmouth	5	320	340	328	(9)	5	<0.003	<0.003	<0.003	✓	5	<0.002	<0.002	<0.002	✓
Gascoyne Junction	4	36	100	65	✓	4	<0.003	0.004	<0.003	✓	4	<0.002	<0.002	<0.002	✓
Geraldton	7	110	120	119	✓	7	0.015	0.030	0.024	✓	7	<0.002	0.002	<0.002	✓
Gingin	5	31	32	32	✓	5	0.080	0.120	0.096	✓	5	0.002	0.003	0.002	✓
Greenhead	2	100	120	110	✓	2	0.015	0.060	0.038	✓	2	<0.002	<0.002	<0.002	✓
Guilderton	4	330	350	340	(9)	4	<0.003	0.100	0.025	✓	4	<0.002	<0.002	<0.002	✓
Horrocks	4	130	140	133	✓	4	0.030	0.035	0.031	✓	4	0.003	0.006	0.005	✓
Jurien Bay	18	240	450	314	(9)	18	<0.003	0.004	<0.003	✓	18	<0.002	<0.002	<0.002	✓
Kalbarri	2	51	65	58	✓	2	0.004	0.010	0.007	✓	2	<0.002	<0.002	<0.002	✓
Lancelin	4	280	300	293	(9)	4	<0.003	0.004	<0.003	✓	4	<0.002	<0.002	<0.002	✓
Latham	5	80	99	93	✓	5	0.010	0.030	0.019	✓	5	<0.002	<0.002	<0.002	✓

(9) Elevated hardness is characteristic of the source supplying this locality.

(10) Elevated iron associated with short-term operational changes or as a result of distrupction to pipework in association with historic iron build up in pipes.

Drinking Water Quality Annual Report Data 01/07/2024 to 30/06/2025

Table 10 Aesthetic (non-health related) variables															
Mid West Region	Hardness					Iron					Manganese				
Locality	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met
		Min	Max	Mean			Min	Max	Mean			Min	Max	Mean	
Ledge Point	4	230	260	245	(9)	4	<0.003	0.004	<0.003	✓	4	<0.002	<0.002	<0.002	✓
Leeman	2	100	110	105	✓	2	0.015	0.030	0.023	✓	2	<0.002	<0.002	<0.002	✓
Meekatharra	2	49	50	50	✓	2	<0.003	0.015	0.008	✓	2	<0.002	<0.002	<0.002	✓
Mingenew	4	94	110	101	✓	4	0.010	0.080	0.038	✓	4	<0.002	0.005	<0.002	✓
Moora	2	65	80	73	✓	2	0.015	0.050	0.033	✓	2	<0.002	0.002	<0.002	✓
Morawa	5	53	83	74	✓	5	0.010	0.015	0.014	✓	5	<0.002	<0.002	<0.002	✓
Mt Magnet	5	54	62	58	✓	5	<0.003	0.035	0.009	✓	5	<0.002	<0.002	<0.002	✓
Mullewa	5	120	140	132	✓	5	0.015	0.060	0.036	✓	5	<0.002	<0.002	<0.002	✓
Nabawa	5	120	130	122	✓	5	0.025	0.140	0.061	✓	5	<0.002	0.008	<0.002	✓
New Norcia	13	120	270	177	✓	13	0.030	0.140	0.056	✓	13	<0.002	0.004	<0.002	✓
Nilgen (Ocean Farms)	3	200	220	213	(9)	3	0.006	0.006	0.006	✓	3	<0.002	<0.002	<0.002	✓
Northampton	5	130	130	130	✓	5	0.030	0.060	0.048	✓	5	<0.002	0.006	0.003	✓
Perenjori	4	75	92	83	✓	4	0.008	0.015	0.012	✓	4	<0.002	<0.002	<0.002	✓
Piawaning	5	100	200	172	✓	5	0.006	0.020	0.010	✓	5	<0.002	<0.002	<0.002	✓
Port Kalbarri	4	110	120	115	✓	4	0.004	0.006	0.005	✓	4	<0.002	<0.002	<0.002	✓
Sandstone	5	30	82	63	✓	5	0.006	0.008	0.007	✓	5	<0.002	<0.002	<0.002	✓
Seabird	2	96	98	97	✓	2	0.030	0.040	0.035	✓	2	<0.002	0.009	0.005	✓
Seaview Park	4	170	220	188	✓	4	<0.003	0.015	0.004	✓	4	<0.002	<0.002	<0.002	✓
Sovereign Hills	5	240	260	252	(9)	5	<0.003	0.010	<0.003	✓	5	<0.002	<0.002	<0.002	✓
Three Springs	5	86	97	90	✓	5	0.025	0.060	0.039	✓	5	0.004	0.012	0.007	✓
Watheroo	4	260	270	268	(9)	4	<0.003	0.015	0.006	✓	4	<0.002	<0.002	<0.002	✓
Woodridge	4	45	46	46	✓	4	0.020	0.035	0.026	✓	4	0.003	0.008	0.005	✓
Yalgoo	5	20	66	41	✓	5	<0.003	<0.003	<0.003	✓	5	<0.002	<0.002	<0.002	✓
Yerecoin	5	100	200	162	✓	5	0.060	0.090	0.072	✓	5	<0.002	<0.002	<0.002	✓
Yuna	5	110	130	120	✓	5	0.070	1.000	0.354	✓	5	0.003	0.040	0.014	✓

(9) Elevated hardness is characteristic of the source supplying this locality.

Drinking Water Quality Annual Report Data 01/07/2024 to 30/06/2025

Table 11 Aesthetic (non-health related) variables															
Mid West Region	pH					Silica					Sodium				
Locality	Samples Taken	Value (pH units)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met
		Min	Max	Mean			Min	Max	Mean			Min	Max	Mean	
Badgingarra	6	6.53	7.07	6.78	✓	6	39.0	44.0	41.7	✓	10	135	160	147	✓
Bindoon /Chittering	2	7.26	7.32	7.29	✓	2	35.0	37.0	36.0	✓	2	120	125	123	✓
Bolgart	4	6.61	6.76	6.69	✓	4	37.0	40.0	38.8	✓	4	125	145	131	✓
Calingiri	14	6.61	7.30	6.91	✓	14	13.0	16.0	14.6	✓	14	185	270	234	(16)
Carnamah	4	6.60	7.14	6.80	✓	4	24.0	26.0	25.0	✓	4	240	260	251	(16)
Carnarvon	2	7.62	7.72	7.67	✓	2	40.0	42.0	41.0	✓	2	71	83	77	✓
Cervantes	4	7.43	7.59	7.54	✓	4	14.0	14.0	14.0	✓	4	165	190	175	✓
Coomberdale	5	8.09	8.73	8.39	✓	5	19.0	23.0	21.0	✓	5	160	165	163	✓
Coorow	5	6.60	7.30	7.06	✓	5	21.0	50.0	28.6	✓	5	225	250	242	(16)
Coral Bay	2	7.62	7.66	7.64	✓	2	<0.2	0.4	<0.2	✓	2	16	17	17	✓
Cue	5	7.89	8.12	8.02	✓	5	75.0	85.0	79.0	✓	5	78	86	82	✓
Dandaragan	5	7.25	7.46	7.33	✓	5	37.0	41.0	39.0	✓	5	185	195	189	(16)
Denham	2	7.88	8.07	7.98	✓	2	1.2	1.8	1.5	✓	2	55	59	57	✓
Dongara/Denison	5	7.10	7.23	7.15	✓	5	21.0	24.0	22.2	✓	5	245	260	252	(16)
Eneabba	4	7.13	7.29	7.20	✓	4	42.0	45.0	43.0	✓	4	175	190	181	(16)
Exmouth	5	7.28	7.66	7.46	✓	5	14.0	18.0	15.8	✓	5	120	130	125	✓
Gascoyne Junction	4	7.22	7.28	7.24	✓	4	4.1	5.0	4.4	✓	4	35	87	59	✓
Geraldton	7	6.96	7.31	7.05	✓	7	21.0	24.0	22.6	✓	7	240	265	253	(16)
Gingin	5	7.09	7.43	7.22	✓	5	28.0	31.0	29.6	✓	5	64	69	66	✓
Greenhead	2	6.93	7.42	7.18	✓	2	22.0	24.0	23.0	✓	2	145	160	153	✓
Guilderton	4	7.73	7.96	7.85	✓	4	8.7	8.9	8.8	✓	4	225	245	238	(16)
Horrocks	4	7.29	7.58	7.39	✓	4	14.0	15.0	14.8	✓	4	390	415	399	(16)
Jurien Bay	18	7.34	7.67	7.51	✓	18	9.8	15.0	12.9	✓	18	115	370	189	(16)
Kalbarri	2	6.71	6.80	6.76	✓	2	38.0	44.0	41.0	✓	2	92	97	95	✓
Lancelin	4	7.71	7.90	7.80	✓	4	15.0	16.0	15.5	✓	4	115	140	129	✓
Latham	5	7.10	9.15	8.68	(11)	5	41.0	47.0	43.6	✓	5	190	210	200	(16)

(11) Elevated pH due to long mains supplying this locality.

(16) Elevated sodium is characteristic of the source supplying this locality.

Drinking Water Quality Annual Report Data 01/07/2024 to 30/06/2025

Table 11 Aesthetic (non-health related) variables															
Mid West Region	pH					Silica					Sodium				
Locality	Samples Taken	Value (pH units)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met
		Min	Max	Mean			Min	Max	Mean			Min	Max	Mean	
Ledge Point	4	7.78	8.04	7.93	✓	4	14.0	15.0	14.5	✓	4	92	96	94	✓
Leeman	2	7.05	7.37	7.21	✓	2	22.0	25.0	23.5	✓	2	160	165	163	✓
Meekatharra	2	8.04	8.07	8.06	✓	2	75.0	75.0	75.0	✓	2	88	90	89	✓
Mingenew	4	7.20	7.44	7.32	✓	4	50.0	55.0	52.5	✓	4	220	240	233	(16)
Moora	2	7.30	7.37	7.34	✓	2	21.0	23.0	22.0	✓	2	160	165	163	✓
Morawa	5	7.01	7.40	7.16	✓	5	43.0	48.0	45.0	✓	5	155	215	194	(16)
Mt Magnet	5	8.02	8.08	8.06	✓	5	75.0	80.0	77.0	✓	5	84	94	90	✓
Mullewa	5	7.82	8.05	7.91	✓	5	19.0	25.0	22.2	✓	5	235	260	249	(16)
Nabawa	5	7.58	7.95	7.83	✓	5	21.0	24.0	22.8	✓	5	240	265	254	(16)
New Norcia	13	6.59	7.29	6.95	✓	13	32.0	42.0	35.8	✓	13	205	410	279	(16)
Nilgen (Ocean Farms)	3	7.82	7.90	7.86	✓	3	18.0	18.0	18.0	✓	3	75	82	79	✓
Northampton	5	8.05	8.27	8.16	✓	5	20.0	23.0	22.0	✓	5	255	260	258	(16)
Perenjori	4	6.93	7.45	7.26	✓	4	42.0	49.0	46.0	✓	4	180	210	196	(16)
Piawaning	5	7.18	7.99	7.38	✓	5	15.0	21.0	18.6	✓	5	115	250	197	(16)
Port Kalbarri	4	7.20	7.37	7.28	✓	4	42.0	45.0	43.5	✓	4	225	230	226	(16)
Sandstone	5	7.53	7.66	7.59	✓	5	30.0	38.0	34.6	✓	5	78	100	89	✓
Seabird	2	7.77	7.79	7.78	✓	2	17.0	17.0	17.0	✓	2	145	145	145	✓
Seaview Park	4	7.83	8.25	7.95	✓	4	15.0	17.0	16.0	✓	4	54	94	65	✓
Sovereign Hills	5	7.73	7.96	7.84	✓	5	18.0	20.0	19.2	✓	5	100	110	106	✓
Three Springs	5	7.05	7.48	7.26	✓	5	46.0	49.0	48.0	✓	5	215	225	220	(16)
Watheroo	4	7.42	7.58	7.53	✓	4	12.0	13.0	12.3	✓	4	97	105	101	✓
Woodridge	4	7.04	7.36	7.20	✓	4	23.0	25.0	24.0	✓	4	125	135	131	✓
Yalgoo	5	7.54	7.66	7.61	✓	5	80.0	85.0	84.0	(15)	5	58	86	71	✓
Yerecoin	5	7.27	8.05	7.58	✓	5	16.0	22.0	19.6	✓	5	140	240	194	(16)
Yuna	5	7.62	8.00	7.83	✓	5	21.0	25.0	22.4	✓	5	250	260	257	(16)

(15) Elevated silica is a natural characteristic of the source supplying this locality.

(16) Elevated sodium is characteristic of the source supplying this locality.

Drinking Water Quality Annual Report Data 01/07/2024 to 30/06/2025

Table 12 Aesthetic (non-health related) variables																				
Mid West Region	Sulfate					Total Dissolved Solids					True Colour					Turbidity				
Locality	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Value (TCU)			Guideline Met	Samples Taken	Value (NTU)			Guideline Met
		Min	Max	Mean			Min	Max	Mean			Min	Max	Mean			Min	Max	Mean	
Badgingarra	6	20	22	21	✓	6	509	574	539	✓	6	<1	<1	<1	✓	6	<0.1	0.2	<0.1	✓
Bindoon /Chittering	2	19	20	20	✓	2	479	487	483	✓	2	<1	<1	<1	✓	2	0.1	0.1	0.1	✓
Bolgart	4	21	24	23	✓	4	545	625	567	✓	4	<1	<1	<1	✓	4	0.6	0.7	0.7	✓
Calingiri	14	28	42	37	✓	14	642	911	815	(17)	14	<1	<1	<1	✓	14	<0.1	0.5	<0.1	✓
Carnamah	4	54	55	54	✓	4	818	881	840	(17)	4	<1	<1	<1	✓	4	<0.1	1.1	0.3	✓
Carnarvon	2	54	60	57	✓	2	488	518	503	✓	2	<1	<1	<1	✓	2	<0.1	<0.1	<0.1	✓
Cervantes	4	32	39	36	✓	4	926	1022	972	(17)	4	<1	<1	<1	✓	4	<0.1	0.2	<0.1	✓
Coomberdale	5	26	27	27	✓	5	590	650	609	(17)	5	<1	<1	<1	✓	5	0.2	0.6	0.3	✓
Coorow	5	43	55	51	✓	5	764	870	831	(17)	5	<1	<1	<1	✓	5	<0.1	<0.1	<0.1	✓
Coral Bay	2	2	2	2	✓	2	170	184	177	✓	2	<1	<1	<1	✓	2	<0.1	<0.1	<0.1	✓
Cue	5	18	22	20	✓	5	359	401	377	✓	5	<1	<1	<1	✓	5	<0.1	0.1	<0.1	✓
Dandaragan	5	26	27	27	✓	5	725	796	753	(17)	5	<1	<1	<1	✓	5	0.3	0.4	0.4	✓
Denham	2	2	3	2	✓	2	264	279	272	✓	2	<1	<1	<1	✓	2	<0.1	<0.1	<0.1	✓
Dongara/Denison	5	49	58	54	✓	5	832	946	880	(17)	5	<1	<1	<1	✓	5	0.1	1.2	0.5	✓
Eneabba	4	28	29	29	✓	4	644	670	660	(17)	4	<1	<1	<1	✓	4	0.1	0.2	0.2	✓
Exmouth	5	28	30	29	✓	5	823	874	847	(17)	5	<1	<1	<1	✓	5	<0.1	<0.1	<0.1	✓
Gascoyne Junction	4	21	55	37	✓	4	157	385	259	✓	4	<1	<1	<1	✓	4	<0.1	0.2	<0.1	✓
Geraldton	7	53	57	55	✓	7	828	886	854	(17)	7	<1	<1	<1	✓	7	<0.1	0.2	<0.1	✓
Gingin	5	11	12	12	✓	5	270	286	276	✓	5	<1	<1	<1	✓	5	<0.1	0.3	0.2	✓
Greenhead	2	35	35	35	✓	2	565	591	578	✓	2	<1	<1	<1	✓	2	<0.1	0.2	<0.1	✓
Guilderton	4	51	53	53	✓	4	1104	1139	1118	(17)	4	<1	<1	<1	✓	4	<0.1	<0.1	<0.1	✓
Horrocks	4	91	97	93	✓	4	1276	1326	1305	(17)	4	<1	<1	<1	✓	4	<0.1	0.2	<0.1	✓
Jurien Bay	18	21	77	37	✓	18	695	1637	991	(17)	18	<1	<1	<1	✓	18	<0.1	0.2	<0.1	✓
Kalbarri	2	18	20	19	✓	2	348	403	376	✓	2	<1	<1	<1	✓	2	<0.1	0.1	<0.1	✓
Lancelin	4	21	26	23	✓	4	748	838	800	(17)	4	<1	<1	<1	✓	4	<0.1	<0.1	<0.1	✓
Latham	5	46	51	48	✓	5	667	756	722	(17)	5	<1	<1	<1	✓	5	<0.1	0.2	<0.1	✓

(17) Elevated TDS is characteristic of the source supplying this locality.

Drinking Water Quality Annual Report Data 01/07/2024 to 30/06/2025

Table 12 Aesthetic (non-health related) variables																				
Mid West Region	Sulfate					Total Dissolved Solids					True Colour					Turbidity				
Locality	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Concentration (mg/L)			Guideline Met	Samples Taken	Value (TCU)			Guideline Met	Samples Taken	Value (NTU)			Guideline Met
		Min	Max	Mean			Min	Max	Mean			Min	Max	Mean			Min	Max	Mean	
Ledge Point	4	37	41	39	✓	4	656	685	666	(17)	4	<1	<1	<1	✓	4	<0.1	0.2	<0.1	✓
Leeman	2	36	36	36	✓	2	588	601	595	✓	2	<1	<1	<1	✓	2	<0.1	<0.1	<0.1	✓
Meekatharra	2	20	21	21	✓	2	424	454	439	✓	2	<1	<1	<1	✓	2	<0.1	<0.1	<0.1	✓
Mingenew	4	41	43	42	✓	4	782	832	797	(17)	4	<1	<1	<1	✓	4	0.1	0.1	0.1	✓
Moora	2	26	27	27	✓	2	591	605	598	✓	2	<1	<1	<1	✓	2	<0.1	<0.1	<0.1	✓
Morawa	5	36	51	46	✓	5	554	721	669	(17)	5	<1	<1	<1	✓	5	<0.1	0.1	<0.1	✓
Mt Magnet	5	14	17	16	✓	5	432	466	448	✓	5	<1	<1	<1	✓	5	<0.1	0.2	<0.1	✓
Mullewa	5	49	58	55	✓	5	841	906	884	(17)	5	<1	<1	<1	✓	5	0.2	0.3	0.2	✓
Nabawa	5	52	60	56	✓	5	780	906	865	(17)	5	<1	<1	<1	✓	5	0.1	0.9	0.4	✓
New Norcia	13	30	65	42	✓	13	756	1395	992	(17)	13	<1	<1	<1	✓	13	0.2	0.4	0.3	✓
Nilgen (Ocean Farms)	3	18	18	18	✓	3	604	622	610	(17)	3	<1	<1	<1	✓	3	<0.1	0.4	0.2	✓
Northampton	5	52	58	55	✓	5	865	909	887	(17)	5	<1	<1	<1	✓	5	0.1	0.4	0.3	✓
Perenjori	4	46	51	48	✓	4	652	704	687	(17)	4	<1	<1	<1	✓	4	<0.1	<0.1	<0.1	✓
Piawaning	5	22	61	50	✓	5	491	935	776	(17)	5	<1	<1	<1	✓	5	<0.1	<0.1	<0.1	✓
Port Kalbarri	4	44	46	45	✓	4	798	849	824	(17)	4	1	3	2	✓	4	<0.1	0.2	<0.1	✓
Sandstone	5	13	34	26	✓	5	310	450	393	✓	5	<1	<1	<1	✓	5	<0.1	0.1	<0.1	✓
Seabird	2	34	35	35	✓	2	581	593	587	✓	2	<1	<1	<1	✓	2	<0.1	<0.1	<0.1	✓
Seaview Park	4	13	19	15	✓	4	456	630	503	✓	4	<1	<1	<1	✓	4	<0.1	0.3	0.2	✓
Sovereign Hills	5	17	18	17	✓	5	680	714	695	(17)	5	<1	<1	<1	✓	5	<0.1	0.3	<0.1	✓
Three Springs	5	42	44	43	✓	5	713	773	750	(17)	5	<1	<1	<1	✓	5	0.1	0.4	0.2	✓
Watheroo	4	18	20	19	✓	4	671	682	678	(17)	4	<1	<1	<1	✓	4	<0.1	<0.1	<0.1	✓
Woodridge	4	36	37	37	✓	4	473	493	481	✓	4	<1	<1	<1	✓	4	<0.1	0.2	<0.1	✓
Yalgoo	5	2	12	6	✓	5	302	452	368	✓	5	<1	<1	<1	✓	5	<0.1	0.2	<0.1	✓
Yerecoin	5	29	57	48	✓	5	578	889	752	(17)	5	<1	<1	<1	✓	5	0.1	0.4	0.2	✓
Yuna	5	52	56	55	✓	5	847	883	870	(17)	5	<1	<1	<1	✓	5	0.4	23	5.7	✓

(17) Elevated TDS is characteristic of the source supplying this locality.