

Standard Signage for Treatment & Chemical Dosing Plants

DANGEROUS GOODS COMBUSTIBLE LIQUID STORE (Storage container exceeding 500L)

COMBUSTIBLE LIQUID PLACARD (DS WCSS023-1)



This **Combustible Liquid Placard** has black text on a white or silver background.
Material: Metal or Vinyl – Minimum TBD (W) x 150 (H) with the other dimensions as indicated.
Note: The width dimension is dependent on the size of the tank, but the text height shall be no less than 100mm in size

- The **Combustible Liquid** placard shall be posted on the bulk storage tank(s).
- The **Combustible Liquid** placard can also be posted on a free-standing post adjacent to the storage area or near the fill point (for larger installations).
- The **Combustible Liquid** placard shall be displayed at a level so that it is visible from the normal direction of approach.

Notes: The GHS pictograms for Health Hazard (aspiration & carcinogenicity) and Warning (exclamation mark) shall also be placed separate to this placard (just below).

Combustible Liquid (i.e. diesel) means a liquid that is not a Class 3 (i.e. petrol) dangerous good that has —

- (a) a flashpoint that is no higher than 93°C; and
- (b) a fire point, as defined in AS 1940:2017, that is less than the boiling point.