

***REVISIONS TO DS63 WATER RETICULATION DESIGN STANDARD***

Delete 2<sup>nd</sup> bullet point of Clause 4.4.3.2, i.e.

~~A minimum horizontal clearance of 250mm shall be maintained between the main and any other existing or proposed services;~~

Replace Clause 4.4.3.3 with:

**4.4.3.3 Other Services**

A minimum vertical clearance of 150mm and minimum horizontal clearance of 250mm (both measured wall-to-wall) must be maintained at all times with other services unless the other service owner has greater clearance requirements (for example, 300mm is the minimum required clearance with electrical services in accordance with AS 3000), in which case the greater of the two clearance requirements shall be met. Flanges and other appurtenances of greater diameter than the pipe shall not be located at pipe crossings.

Enquiries regarding the above revisions can be directed to  
[Engineering.StandardsEnquiries@watercorporation.com.au](mailto:Engineering.StandardsEnquiries@watercorporation.com.au).