


Approval certificate

Trade waste pre-treatment product



Applicant: DuluxGroup Ltd
Postal address: PO Box 60, Clayton South, VIC, 3169

Attention: Mark Taylor
Web: www.dulux.com.au
Email: mark.z.taylor@dulux.com.au

Manufacturer: DuluxGroup Ltd
Address: PO Box 60, Clayton South, VIC, 3169

Product/device description

The Dulux range of *EnviroWash Systems* are treatment systems that turn paint wash-out into clean water and inert solid waste for safe disposal.

The treatment systems are designed as stand-alone systems that do not typically require connection to sewer.

The acceptance certificate applies to the pre-treatment device tabulated below:

Approval Number	Model	Description	Max Loading Capacity	Material of Construction
AN-040-01	ES 160 P	Water Based Paint Wash-Out and Water Treatment System – with pump	160 L	PE container
AN-040-02	ES 800	Water Based Paint Wash-Out and Water Treatment System	800 L	PE container in mild steel pipe frame

Special conditions of approval

1. **This product is for use with water based paints and coatings only. Not suitable for oil or solvent based paints.**
2. **The paint washout systems must be used only at the end of the working day or working week to allow proper reaction and settling of solids material.**
3. The ES 160 P paint washout system must be correctly dosed as per manufacturer's instructions by use of the manufacturer's supplied measuring cup.
4. The ES 800 paint washout system must be correctly dosed as per manufacturer's instructions by use of the manufacturer's supplied and single use pre-weighed sachets.
5. The product shall be *supplied* with manufacturer's installation instructions and recommended procedures for operation and maintenance.
6. The product shall be *installed* strictly in accordance with the manufacturer's written instructions and performed by a licensed plumber.
7. A *maintenance* contract is to be in place to ensure the ongoing reliability of the product.
8. Water Corporation must be notified within fourteen (14) days upon installation of the product.
9. Clear access for the purposes of maintenance or servicing of the product must be maintained at all times.
10. This approval certificate is not an endorsement of the product by Water Corporation, and no claim shall be made in advertising, promotion or other manner to the effect.
11. Water Corporation accepts no responsibility for the effective operation, performance or efficiency of the product.
12. The proponent of the approved product must formally seek a request for re-approval of the product no later than three (3) months before the assigned **Validity Period** has expired from the **Date Issued** of this approval certificate.
13. Water Corporation reserves the right to vary any requirements at any time. Any application of this condition normally occurs after consultation with the manufacturer, supplier and end business user connected to Water Corporation's sewer.
14. Water Corporation shall be notified in writing if the product is withdrawn from sale.
15. The proponent of the approved product accepts that the information provided in this document shall be made publically available.

Approval certificate

Trade waste pre-treatment product



General conditions of approval

Approval shall be **suspended** where any of the following conditions are not met:

1. If there is a breach of the Special Conditions.
2. The assigned **Validity Period** has expired from the **Date Issued** of this approval certificate.
3. The product shall be manufactured in accordance with Water Corporation's requirements at the time of approval.
4. The product shall be manufactured to comply according to the details noted in *EnviroSolutions product use brochure*, in addition to any further details provided by the proponent when seeking this approval.
5. The product supplied for use in Water Corporation's area of operations shall comply with the requirements shown on this approval certificate. Sizes, classes, lengths or other product variables which are available with the product but which are not approved as listed on this approval certificate shall not be offered by the supplier for use in Water Corporation's area of operations.
6. All discharges to sewer associated with this product must not exceed Water Corporation's *Trade Waste Acceptance Criteria*.
7. Prior to any business (which is connected to Water Corporation's sewer) installing this product the business must apply to Water Corporation for a *Trade Waste Permit* for approval to discharge.
8. If this certificate has been issued to the manufacturer of this product then it is the responsibility of the manufacturer to ensure all current and future suppliers / vendors of this product are provided a copy of this approval certificate.

Approval shall be **reviewed** where any of the following conditions occur:

1. The product is manufactured with either different materials, methods of manufacture, location of manufacture, source of raw materials, component subcontractors or models to that at the time of approval.
2. The ownership of the primary manufacturer or any subcontractors is varied from that at time of approval.
3. The standards and/or specifications to which the product was required to comply with at the time of approval have been amended or revised. It is the responsibility of the proponent to immediately advise Water Corporation of any changes to the proponent's drawings and installation, operation and maintenance manuals made at the time of approval.
4. The product has been found to sustain damage or provide unsatisfactory performance on occasions of number considered excessive by Water Corporation, when handled, stored, assembled or installed in accordance with the supplier's or manufacturer's written instructions.

Approved drawing(s):	Not applicable.
Authorising person:	Stephen Jerkovic (Team Leader – Investigations)
Date issued	20 December 2018
Validity period:	Five (5) years