


Approval certificate

Trade waste pre-treatment product



Applicant: Coerco Pty Ltd
Postal address: PO Box 319 Dalwallinu WA 6609

Manufacturer: Coerco Pty Ltd
Address: PO Box 319 Dalwallinu WA 6609

Attention: Todd Kirkness
Web: www.group.coerco.com.au
Email: todd.kirkness@coerco.com.au

Product description

The Coerco passive grease arrestor is designed to trap and remove grease, fat and oil from commercial kitchens. Coerco tanks are a one-piece construction manufactured from UV stabilised polyethylene (LLDPE) material. The product can be installed below and above ground.

A maximum of two units in series (based upon the GA1200 and GA2000 models only) can be arranged to form 2400 to 4000 litre operating capacities for installations within Water Corporation's area of operations.

Any proposed installation of a GA4000 unit is first subject to a formal Water Corporation Trade Waste plumbing assessment (and approval) of the overall waste stream processes to determine if the selected unit is the most appropriate form of pre-treatment. The GA4000 units can only be installed as single units.

The approval certificate applies to the pre-treatment product of the following sizes:


Approval Number	Model	Installation Type ¹	Capacity (L)	Width ² (mm)	Length ² (mm)	Height ³ (mm)	Access Lid Type	Inlet/Outlet Diameter (mm)	Inlet Height ⁶ (mm)	Outlet Height ⁶ (mm)
AN-093-02	GA1200	Both	1267	1000	2500	1595	Sealed screw poly-lid ⁴ or Cast iron or composite type ⁵	100	910	810
AN-093-01	GA2000	Both	1861	1224	2498	1768	Sealed screw poly-lid ⁴ or Cast iron or composite type ⁵	100	1100	1010
AN-093-03	GA4000 ^{7,8}	Both	4210	1800	2500	2445	Sealed screw poly-lid ⁴ or Cast iron or composite type ⁵	100	1670	1570

1: Above or Below Ground; 2: External; 3: Not including lid cover; 4: (i) Above and (ii) Below ground (non-trafficable vehicle area, pedestrian access only); 5: Below ground (trafficable vehicle area); 6: From base of tank; 7: The GA4000 unit can only be installed as a single unit; 8: Where the installation of the GA4000 unit is proposed then a formal Water Corporation Trade Waste plumbing assessment of the overall waste stream processes must first be made (and approved) to determine if the GA4000 unit is the most appropriate form of pre-treatment.

Special conditions of approval

1. The product shall be *supplied* with manufacturer's installation instructions and recommended procedures for operation and maintenance.
2. The product shall be *installed* and *maintained* strictly in accordance to the following Coerco documentation:
 - a. Grease Arrestor Product Information, Installation and Warranty Manual (10 Nov 2022 – Revision F)
3. This approval certificate is not a stand-alone document and **must be read** in conjunction with the following Water Corporation documents:
 - a. [Typical Drawings for Trade Waste – Grease Arrestor \(HX33-10-00\)](#)
 - b. [Typical Drawings for Trade Waste – Trade Waste Sampling Point \(HX33-11-30\)](#)
 - c. [Typical Drawings for Trade Waste – Venting of Grease Arrestors and Sealed Trade Waste Sampling Points \(HX33-10-10\)](#)
 - d. [Grease Arrestor Installation Guidelines](#)
4. A maintenance contract is to be in place to ensure the ongoing reliability of the product.
5. Water Corporation must be notified within fourteen (14) days upon installation of the product
6. The use of emulsifying agents upstream of the product must not occur. Such instructions must be noted on operating documentation.
7. The product chosen must be suitably sized to avoid surge conditions.
8. Clear access for the purposes of maintenance or servicing of the pre-treatment device must be maintained at all times.
9. This approval certificate is not an endorsement of the product by Water Corporation, and no claim shall be made in advertising, promotion or other manner to the effect.
10. Water Corporation accepts no responsibility for the effective operation, performance or efficiency of the product. This approval is not an engineering approval or structural endorsement.

Approval certificate



Trade waste pre-treatment product

Special conditions of approval (continued)

11. The proponent of the approved product must formally seek a request for re-approval of the product no later than three (3) months before the assigned **Validity Period** has expired from the **Date Issued** of this approval certificate.
12. Water Corporation reserves the right to vary any requirements at any time. Any application of this condition normally occurs after consultation with the manufacturer, supplier and end business user connected to Water Corporation's sewer.
13. Water Corporation shall be notified in writing if the pre-treatment device is withdrawn from sale.
14. The proponent of the approved product accepts that the information provided in this document shall be made publicly available.

General conditions of approval

Approval shall be **suspended** where any of the following conditions are not met:

1. If there is a breach of the Special Conditions.
2. The assigned **Validity Period** has expired from the **Date Issued** of this approval certificate.
3. The product shall be manufactured in accordance with Water Corporation's requirements at the time of approval.
4. The product shall be manufactured to comply according to the details noted in *Grease Arrestor Product Information, Installation and Warranty Manual (10 Jan 2023 – Revision G)*, in addition to any further details provided by the proponent when seeking this approval.
5. The product supplied for use in Water Corporation's area of operations shall comply with the requirements shown on this approval certificate. Sizes, classes, lengths or other product variables which are available with the product but which are not approved as listed on this approval certificate shall not be offered by the supplier for use in Water Corporation's area of operations.
6. All discharges to sewer associated with this product must not exceed Water Corporation's *Trade Waste Acceptance Criteria*. Where the discharge *has* or is *likely* to exceed the *Trade Waste Acceptance Criteria* then the Corporation may direct a *specific* or *ongoing* maintenance requirement to be followed.
7. Prior to any business (which is connected to Water Corporation's sewer) installing this product the business must apply to Water Corporation for a *Trade Waste Permit* for approval to discharge.
8. If this certificate has been issued to the manufacturer of this product then it is the responsibility of the manufacturer to ensure all current and future suppliers / vendors of this product are provided a copy of this approval certificate.

Approval shall be **reviewed** where any of the following conditions occur:

1. The product is manufactured with either different materials, methods of manufacture, location of manufacture, source of raw materials, component subcontractors or models to that at the time of approval.
2. The ownership of the primary manufacturer or any subcontractors is varied from that at time of approval.
3. The standards and/or specifications to which the product was required to comply with at the time of approval have been amended or revised. It is the responsibility of the proponent to immediately advise Water Corporation of any changes to the proponent's drawings and installation, operation and maintenance manuals made at the time of approval.
4. The product has been found to sustain damage or provide unsatisfactory performance on occasions of number considered excessive by Water Corporation, when handled, stored, assembled or installed in accordance with the supplier's or manufacturer's written instructions.

Approved drawing(s): 1200 L GA Layout – AG (C-GA1200A-001 & -002; 27 Jul 2022)
1200 L GA Layout – BG (C-GA1200-001 & -002; 20 Sep 2022 & 27 Jul 2022 respectively)
2000 L GA Layout – AG (C-GA2000A-001 & -002; 25 Jul 2022)
2000 L GA Layout – BG (C-GA2000B-001 & -002; 25 Jul 2022)
4000 L GA Layout – AG (C-GA4000A-001 & -002; 25 Jul 2022)
4000 L GA Layout – BG (C-GA4000-001 & -002; 20 Sep 2022 & 29 Sep 2022 respectively)

Authorising person: Stephen Jerkovic (Team Leader – Investigations)

Date issued 18 January 2023

Validity period: Two (2) years