

Installation guide – appendix

LIPUMAX PPE GREASE TRAP – state water authorities

VERSION NO.	IMPLEMENTED BY	REVISION DATE	REASON
1	John Sordo	3 OCTOBER 2023	Water Corporation, Sydney Water and SA Water supplements



Contents

1 WATER AUTHORITY APPROVALS	3
--	----------

1 WATER AUTHORITY APPROVALS

WATER CORPORATION (supplement)

- Refer to drawings HX33-10-10 & HX33-10-30 for precise construction requirements for Trade Waste Sampling Point (TWSP).
- Only camlock fittings are to be used for pump out line and no fixed suction is to be installed.
- A baffle cap is required to be installed as to manufacturer's instructions on the outlet baffle to prevent surcharge. Riser tubes are optional. Refer to table below for ordering information.
- A hose tap fitted with a backflow prevention device must be located within 5 metres of the grease trap for cleaning purposes (as per AS/NZS 3500).
- For grease trap installation include adequate backflow prevention guidelines, refer to Water Corporation *Grease Arrestors Installation Guidelines (Information Sheet 23B)*.
- The grease trap model and size can be identified on the trap and an external label:

Lipumax accessories table

Part No.	Description	Weight (kg)
142350	Riser tube (short)	22.0
142970	Riser tube (long)	48.0
142105	Baffle cap to suit 110 Ø inlet/outlet	0.1
142106	Baffle cap to suit 160 Ø inlet/outlet	0.1

SYDNEY WATER (supplement)

- Grease traps are to be cleaned out at a minimum interval of 6 months, depending on usage.

SA Water (supplement)

- A baffle cap is required on the outlet baffle to prevent surcharge.
-