• A 265 metre long section of 90mm and 75mm diameter sewer pressure mains in a common trench, between Woods Drive and Port Drive within the existing access track. CONNECTING TO EXISTING ACCESS • A 235 metre long section of 225mm diameter underground gravity CHAMBER AD8285 OF PUMP STATION WWPS 8 (PS247-08) sewer pipeline. Connecting to the existing wastewater pumping station at Dann Place. PROPOSED MAINTENANCE SHAFT -• A below ground maintenance shaft and discharge chamber LOCATED IN EXISTING TRACK PROPOSED DISCHARGE CHAMBER It is expected that construction will start from March 2023 and take PROPOSED 75mm WASTEWATER PRESSURE MAIN LOCATED IN EXISTING TRACK two months to complete. The pipes will be installed by open trench excavation and the area will EXISTING 80mm AND 65mm WASTEWATER PRESSURE MAINS be backfilled and restored. The Port Drive crossing will be constructed by underground horizontal directional drilling. SHIRE OF BROOME Objections to the proposal will be considered if lodged in writing and address to the Project manager within 21 days of the issue of the accompanying letter. Further information is available by contacting Project Manager, Luke BROOME VACATION CARAVAN PARK Dalton on (08 9420 3658). SN LOCATION OF WORKS LEGEND PROPOSED 75mm WASTEWATER PRESSURE MAIN 4 ---- PROPOSED 90mm WASTEWATER PRESSURE MAIN PROPOSED GRAVITY SEWER Z Z Z -w---w-- EXISTING WATER MAIN -- PM --- PM -- EXISTING WASTEWATER PRESSURE MAIN LOCALITY PLAN ---s--- EXISTING GRAVITY SEWER HABITAT RESORT BROOME PREL N. 8011286.54 m PLAN SCALE 1:5000 (1:5000)SEWERAGE RETIC 4A + BROOME PRIVATE PS & RM FOR EDEN ISSUED FOR CLIENT COMMENT RECOMMENDED NONE SHEET CARAVAN PARK LOT 1783 PORT DR COORDINATE SYS DES CHD PREREQUISITES TO WORK CONSULTANT PROJECT MANAGER NOTICE OF PROPOSAL - GENERAL WORKS ASCON SURVEY APPROVED T.MORGEN CAD ISSUE Level 10, 999 Hay Street Perth WA 6000 Australia GHD AW82 - 0 - 18T 61 8 6222 8222 F 61 8 6222 8555 12583539 Q.C. CHD DRN | REC | APPD SSUE | DATE | GRID **REVISION** PROJECT CS03549 E permail@ghd.com W www.ghd.com CONSULTANT PROJECT DIRECTOR HDNET\GHD\AU\PERTH\PROJECTS\61\12583539\CADD\DRAWINGS\AW82-000-018-01A2 21/10/2022 THIS DRAWING IS THE PROPERTY OF THE WATER CORPORATION. IT SHALL NOT BE COPIED WITHOUT PERMISSION.

BROOME SOUTH WASTEWATER: SHIRE OF BROOME

NOTICE OF PROPOSAL TO DIVERT TWO UNDERGROUND WASTEWATER PRESSURE MAINS

To maintain wastewater services for two private properties when Broome

South Wastewater Treatment Plant is decommissioned, Water Corporation

proposes to install:

N. 8013399.70m